

PRESSURE EQUIPMENT DIRECTIVE (PED) 2014/68/EG

We herewith declare that all pressure sensors labeled HUBA CONTROL comply with all legal normative and functional requirements.

For all pressure sensors which do not dispose of a CE conformity declaration for the pressure equipment directive 2014/68/EG the following is applicable in accordance with this directive.

Pressure sensors with max. pressure of ≤ 0.5 bar are not concerned.

According article 4 (1) d) pressure sensors with max. nominal pressure of > 0.5 bar shall not be in use as safety and pressure accessories. So as they are not to declare as 'pressure-bearing pressure accessories' according to article 2, (5) and Guideline A-25 of PED Directive


The pressure volume available $P_s \cdot V$ is significant lower than $50 \text{ bar} \cdot \text{l}$ and pressure P_s is ≤ 1000 bar.

According article 4 (3) products shall be designed and manufactured in accordance with a sound engineering practice. The detailed operation manual is enclosed to each product.

Hence under this pressure equipment directive a CE declaration and identification is not necessary and shall not be carried out regardless to other harmonization directives of the European Union.

Würenlos, 12.07.2016

HUBA CONTROL AG



Daniel Hitz
Quality Manager



Lothar Sterner
Certification Specialist